



Assumptions:

- 1) Only Incoming Water RO and Chemical Treated
- 2) Condensed Steam treated for PH and ?
- 3) Flow of Chlorine and RO sized to meet maximum demand
- 4) Tank if feasible to accommodate larger peak demand

Need to Know From Customer:

- 1) Average Input Flow
- 2) Amount of draw down
- 3) Acceptable time to refill after blow down